



Government Of West Bengal
Office Of The Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services
C. R. Das Road, P.O.+P.S. :- Berhampur, Pin :- 742101

Memo no.:FES/MSD/40/2017

Date: 03-04-2023

From:
Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

To: St. Stephen's Iconic School
Plot No-R.S-904, L.R-1201, J.L.No-17, Vill-Natungram Pirtala, P.O and P.S-Murshidabad, Pin-742149.

Sub: Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+II storied building under group of Educational Building at the premises No. "St. Stephen's Iconic School" over Plot No-R.S-904, L.R-1201, J.L.No-17, at Vill-Natungram Pirtala, P.O and P.S-Murshidabad, W.B, Pin-742149

This is in reference to your application no. 0125191230900029 dated 20-03-2023 regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G+II storied building under group of Educational Building at the premises No. "St. Stephen's Iconic School" over Plot No-R.S-904, L.R-1201, J.L.No-17, at Vill-Natungram Pirtala, P.O and P.S-Murshidabad, W.B, Pin-742149

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1.Fire notice for the fighting and the evacuation from the building shall be prepared places of the building.
- 2.Another one number staircase RCC shall provided within 60 days from date of issue.
- 3.DirectionaI sigh and of escape routes shall be displayed prominently.
- 4.All staff / employs will be conversant with installed firefighting equipment of the building and to operate in the event of firetesting.
- 5.Arrangement shall be made for regular checking, testing and maintained of all fire safety installation equipment in the

building to keep them in perfectly good working condition at all time.

6.Eclectic Line / meter box should be checked Regd. Electrician proper repair should be made, if required.

7.Always main gate is to be made free and should be engaged a person for maintenance of the gate.

8.Always on the ground Reservoir should be filled up the water. A jockey pump is to be active and the person for operating should pump be engaged.

9.Cooking arrangement is strictly prohibited in the building.

10.Every Three years a certificate is to be obtained from the West Bengal Fire & Emergency Services Department certifying about the satisfactory service, but all fire safety measure shall be checked and found ok by the authorized Vendor each year must. The performance of all life and safety arrangement and installation of the building.

Divisional Fire Officer, Murshidabad
West Bengal Fire & Emergency Services

Memo No.: FES/MSD/40/2017